

CHECKLIST FOR THE WRITTEN SCHEME TO BE COMPILED FOR EACH LPG INSTALLATION

The Written Scheme of Examination shall include the following:

CHECKLIST	Mark if information is available only
Identification of the Authorised provider and plant manager (if different)	<input type="checkbox"/>
Identification of the item of plant or equipment;	<input type="checkbox"/>
The maximum interval between Routine inspections;	<input type="checkbox"/>
The maximum interval between Periodic inspections;	<input type="checkbox"/>
The maximum interval between Requalification;	<input type="checkbox"/>
Information about those parts of the system which are to be examined, including, but not necessarily limited to the pressure vessel, its safety devices and mountings;	<input type="checkbox"/>
The nature of the examination required, including the inspection and testing to be carried out on any protective devices; Competent Person is to declare the person that is going to be responsible for the routine inspection, periodic inspection and requalification tests.	<input type="checkbox"/>
The critical parts that, if modified or repaired, shall be inspected by a competent person/body before they can put back into service;	<input type="checkbox"/>
The requirements for pressure relief valves <ul style="list-style-type: none">○ a test of the set pressure of the pressure relief valve and, for an external pressure relief valve, a check on the condition of the spring; or○ the pressure relief valve shall be replaced with a new or reconditioned valve if required.	<input type="checkbox"/>
The safe operating limits;	<input type="checkbox"/>
The name of the competent person/body preparing the written scheme;	<input type="checkbox"/>
The date of the preparation of the written scheme.	<input type="checkbox"/>
Scheme is endorsed by Authorised provider	<input type="checkbox"/>
Competent Person is required to declare that training and provision of written procedures of the authorised LPG Installation is to be given to the Authorised Person	<input type="checkbox"/>

On the notice letter given to the applicant, the Regulator will be requesting the following:

- Written Scheme of Examination as per COP A2, EN12817 and EN12819.
- Scheme to be endorsed by Authorised person.